

**TAMILNADU FIRE AND RESCUE SERVICE
NO OBJECTION CERTIFICATE**

R.C.NO: 152 /V/VDM/2024

DATE: 12.04.2024

SUB :

Fire And Rescue Services- Vriddhachalam - Fire & Rescue Station – Issue No Objection,
To Run School ----- Regarding.

REF :

1. GOMS NO :122 School Education (2) Department Date:14.09.2004.
2. GOMS NO :123 School Education (2) Department Date:14.09.2004.
3. The Principal Antony Public School application received On 10.04.2024.

With refference to the above , the premises R.S.No : 141/1 (P) Cuddalore to vriddhachalam main road , Pudhukooraipet village, Sathamangalam post, Vriddhachalam & Taluk, Cuddalore District was Inspected by Mr. G .SANKAR , STATION OFFICER Virddhachalam On 12.04.2024 to run school in the name and the style of ANTONY PUBLIC SCHOOL No Objection Is hereby granted in the view of fire points.

CONDITIONS:

- 1 . This certificate is valid upto one year from the date of issue ,next due on 11.04.2025.
- 2 . All the Extinguishers have to be recharged and maintained periodically as per code Practice in 2190 : 2010.
3. As GOMS No: 713 Home (Police -17) Date :17.08.2005 All Staff Should have basic Fire Fighting Training.
4. Mock drill should be conducted with fire department.
5. Hose reel system should be provided.

OFFICE SEAL:



S. Sankar 12/24
**STATION OFFICER,
FIRE AND RESCUE SERVICE
VIRUDHACHALAM-606 001.**

TO:

The Principal,
Antony public School,
Pudhukooraipetai,
Sathamangalam post,
Vriddhachalam taluk.

COPY:

The District Officer, Cuddalore District.